



GSA INTERNATIONAL

Certificate of Compliance

Certificate: 1336093 (LR 48471-202)

Master Contract: 171938

Project: 2109885

Date Issued: 2008/11/25

Issued to: Tyco Electronics EC K.K.
3-5-8 Hisamoto
Takatsu-Ku
Kawasaki, Kanagawa 213-8535
Japan
Attention: Yoshihisa Oikawa

The products listed below are eligible to bear the CSA Mark shown



Issued by: John Lam

Authorized by: Nick Alfano, Operations
Manager

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Relays, Type PCH with suffixes, open type with dust cover, spst or spdt, rated 5A(NO), 3A(NC), 30 V dc/277V ac resistive; TV-3(NO); coils 3 to 48V dc.

Note: Open type relays are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by the CSA International.